

TEST REPORT

K4 Soils Laboratory




Sample Details

Certificate of sampling received: No
Laboratory Ref No: K4-30149 - 6F5/3103/01
Client Ref No: 6F5/3103/01 - SRH-Mar21
Sampling Location: Seal Road Haulage - WRAP Compliance Testing March 2021
Name of Source: Seal Road Haulage - WRAP Compliance Testing March 2021
Date Sampled: 30/04/2021
Date Received: 21/05/2021
Date Tested: 09/07/2021
Method of Sampling: Samples taken By Kalex
Material Description: FMC Crushed Concrete with brick fragments and sandy fines
NMC (%): 8.2
Target Specification: SHW Series 600: Table 6/1 and Table 6/5
Class 6F5 - Selected Granular Material - (fine grading) - imported on to the site - Capping

Results:

Unrepresentative lumps were present : **NO**

BS Test Sieve	Cumulative Percentage Passing	Specification limits	
125.0	100	100	100
80.0	81	75	99
40.0	66	50	90
20.0	54	30	75
10.0	35	15	60
2.0	19	0	35
0.063	2.9	0	12



Sample complies with specification limits: **YES**



Particle Size Distribution BS EN 933-1: 2012

Determination of particle size distribution of aggregate sample-washing and sieving method

Checked and Approved

Initials: J.P
14/07/2021

Test Report by K4 SOILS LABORATORY Unit 8 Olds Close Olds Approach Watford Herts WD18 9RU

Test Results relate only to the sample numbers shown above. Approved Signatories: K.Phaure (Tech.Mgr) J.Phaure (Lab.Mgr)

All samples connected with this report, incl any on 'hold' will be stored and disposed off according to Company policy. A copy of this policy is available on request.